

PERSONAL PROTECTIVE EQUIPMENT

HAND PROTECTION

# **NVES** REGELTEX

## **PNEUMATIC TESTER**

**Article No.: 67184RG398** 

The pneumatic tester is a pump system optimizing inflation and thus visual inspection, especially at the cuff level.



### **SPECIFICATIONS**

Before using insulating gloves for live working, the EN 60903:2003 and IEC 60903:2002 standards recommend a visual inspection by inflating the gloves with air to detect any possible leakages.

In view of the thickness of the gloves class 1, 2, 3 and 4, inflation by the tester is not appropriate. For these gloves, inspection of the inside and outside surfaces must be done. An electric test every six months is strongly recommended.

#### **APPLICATIONS**

· Use in live working electrical works

#### **STANDARDS**






EN 60903:2003 IEC 60903:2002









This Article Data Sheet (ADS) is designed and produced by FLOWTRONIX (FT) covered under the intellectual property law. Any reproduction in whole or in part is strictly prohibited without written approval. FT HG 5141-3.2



